



**BATANGAS II ELECTRIC COOPERATIVE, INC.**

Antipolo del Norte, Lipa City



(043) 756 6337; 757 0951

<b>Daily Supply and Load Demand Outlook</b>			
March 19, 2022			
<b>(MW)</b>	<b>Morning</b>	<b>Afternoon</b>	<b>Evening</b>
	0001H to 1200H	1201H to 1800H	1801H to 2400H
Power Supply	86.25	95.20	107.95
Maximum Load Demand	136.94	141.59	142.26
Power Supply Reserve (Deficit)	50.69	46.39	34.31

Note/s:

The deficit will be source out from WESM as there trading intervals with competetive spot prices.