



BATANGAS II ELECTRIC COOPERATIVE, INC.

Antipolo del Norte, Lipa City



(043) 756 6337; 757 0951

Daily Supply and Load Demand Outlook			
July 2, 2022			
(MW)	Morning	Afternoon	Evening
	0001H to 1200H	1201H to 1800H	1801H to 2400H
Power Supply	95.44	113.68	107.60
Maximum Load Demand	125.89	126.56	126.68
Power Supply Reserve (Deficit)	30.45	12.89	19.08

Note/s:

The deficit will be source out from WESM as there trading intervals with competetive spot prices.