



BATANGAS II ELECTRIC COOPERATIVE, INC.

Antipolo del Norte, Lipa City

☎ (043) 756 6337; 757 0951

| Daily Supply and Load Demand Outlook | | | |
|--------------------------------------|----------------|----------------|----------------|
| September 20, 2024 | | | |
| (MW) | Morning | Afternoon | Evening |
| | 0001H to 1200H | 1201H to 1800H | 1801H to 2400H |
| Power Supply | 106.84 | 109.50 | 107.89 |
| Maximum Load Demand | 151.00 | 149.60 | 154.24 |
| Power Supply Reserve (Deficit) | 44.16 | 40.10 | 46.36 |

Note/s:

The deficit will be sourced-out from WESM as there are trading intervals with competitive spot prices.