



**BATANGAS II ELECTRIC COOPERATIVE, INC.**

Antipolo del Norte, Lipa City



(043) 756 6337; 757 0951

| <b>Daily Supply and Load Demand Outlook</b> |                |                  |                |
|---|----------------|------------------|----------------|
| October 14, 2020                            |                |                  |                |
| <b>(MW)</b>                                 | <b>Morning</b> | <b>Afternoon</b> | <b>Evening</b> |
|   | 0001H to 1200H | 1201H to 1800H   | 1801H to 2400H |
| Power Supply                                | 118.33         | 118.33           | 113.20         |
| Maximum Load Demand                         | 131.99         | 131.03           | 129.27         |
| Power Supply Reserve (Deficit)              | 13.66          | 12.71            | 16.07          |

Note/s:

The deficit will be source out from WESM as there trading intervals with competetive spot prices.