



## BATANGAS II ELECTRIC COOPERATIVE, INC.

Antipolo del Norte, Lipa City

☎ (043) 756 6337; 757 0951

Daily Supply and Load Demand Outlook			
January 6, 2023			
(MW)	Morning	Afternoon	Evening
	0001H to 1200H	1201H to 1800H	1801H to 2400H
Power Supply	109.50	109.50	109.50
Maximum Load Demand	132.37	134.15	137.28
Power Supply Reserve (Deficit)	22.87	24.65	27.78

*Note/s:*

*The deficit will be sourced-out from WESM as there are trading intervals with competitive spot prices.*