



BATANGAS II ELECTRIC COOPERATIVE, INC.

Antipolo del Norte, Lipa City

☎ (043) 756 6337; 757 0951

| Daily Supply and Load Demand Outlook | | | |
|--------------------------------------|----------------|----------------|----------------|
| July 14, 2024 | | | |
| (MW) | Morning | Afternoon | Evening |
| | 0001H to 1200H | 1201H to 1800H | 1801H to 2400H |
| Power Supply | 90.50 | 104.54 | 99.50 |
| Maximum Load Demand | 150.13 | 158.13 | 150.18 |
| Power Supply Reserve (Deficit) | 59.63 | 53.59 | 50.68 |

Note/s:

The deficit will be sourced-out from WESM as there are trading intervals with competitive spot prices.